

Bearing into blockwork cavity wall

All joists to have a minimum bearing of 90mm. Ensure all bearings are flat, level and that the joists are vertical.

Minimum 38*38 perimeter noggin skew nailed or fixed to joist using Z-Clip. Noggin to be 25 - 75mm from face of wall.

Web stiffeners fitted to end of joists. Junction between wall and joists to be sealed with silicon mastic.

Restraint straps may be required for buildings over 2 storeys or where joists have less than 90mm bearing.

